



MSL

DEDICATED HEALTHCARE PARTNERS

Environment of Care areas requiring a Measurement of Success method

EC.02.02.01 EP 5 The hospital minimizes risks associated with selecting, handling, storing, transporting, using, and disposing of hazardous chemicals

EC.02.02.01 EP 9 The hospital minimizes risks associated with selecting, handling, storing, transporting, using, and disposal of hazardous gases and vapors.

EC.02.03.03 EP 4 Staff who work in buildings where patients are housed or treated participate in drill according to the hospital fire response plan.

EC.02.03.05 EP 9 For automatic sprinkler systems: Every week, the hospital tests fire pumps under no-flow conditions.

EC.02.03.05 EP 8 For automatic sprinkler systems: Every month during cold weather, the hospital tests water-storage tank temperature alarms.

EC.02.03.05 EP 15 At least monthly, the hospital inspects portable fire extinguishers. The completion dates of the inspections are documented.

EC.02.04.03 EP 3 The hospital inspects, tests, and maintains non-high-risk equipment. These activities are documented.

EC.02.05.07 EP 1 At least monthly, the hospital performs a functional test of battery-powered lights required for egress for a minimum duration of 30 seconds.

EC.02.06.01 EP 1 Interior spaces meet the needs of the patient population and are safe and suitable to the care, treatment, and services provided.

EC.02.06.01 EP 20 Areas used by patients are clean and free of offensive odors.

EC.02.06.01 EP 26 The hospital keeps furnishings and equipment safe and in good repair.

EC.03.01.01 EP 1 Staff and licensed independent practitioners can describe or demonstrate methods for eliminating and minimizing physical risks in the environment of care.

EC.03.01.01 EP 2 Staff and licensed independent practitioners can describe or demonstrate actions to take in the event of an environment of care incident.

EC.03.01.01 EP 3 Staff and licensed independent practitioners can describe or demonstrate how to report environment of care risks.

EC.04.01.01 EP 3 Based on its processes, the hospital reports and investigates the following: Injuries to patients or others in the hospital's facilities.

EC.04.01.01 EP 4 Based on its processes the hospital reports and investigates the following: Occupational illnesses and staff injuries.

EC.04.01.01 EP 5 Based on its processes the hospital reports and investigates the following: Incidents of damage to its property or property of others.

EC.04.01.01 EP 6 Based on its processes the hospital reports and investigates the following: Security incidents involving patients, staff, or others within its facilities.

EC.04.01.01 EP 8 Based on its processes the hospital reports and investigates the following: Hazardous materials and waste spills and exposures.

EC.04.01.01 EP 9 Based on its processes the hospital reports and investigates the following: Fire Safety management deficiencies, and failures.

EC.04.01.01 EP 10 Based on its processes the hospital reports and investigates the following: Medical/laboratory equipment problems, failures, and use errors.

EC.04.01.01 EP 11 Based on its processes the hospital reports and investigates the following: Utility system management problems, failures, or use errors.

EC.04.01.01 EP 13 The hospital conducts annual environmental tours in non-patient care areas to evaluate the effectiveness of previously implemented activities intended to minimize or eliminate risks in the environment.

EC.04.01.03 EP 2 The hospital uses the results of data analysis to identify opportunities to resolve environmental safety issues.

EC.04.01.05 EP 1 The hospital takes action on the identified opportunities to resolve environmental safety issues.

EC.04.01.05 EP 2 The hospital evaluates changes to determine if they resolved environmental safety issues.