



MSL

DEDICATED HEALTHCARE PARTNERS

Life Safety areas requiring a Measurement of Success method

LS.01.01.01 EP 4 For hospitals that use Joint Commission accreditation for deemed status purposes: The hospital maintains documentation of any inspections and approvals made by state or local fire control agencies.

LS.01.02.01 EP 4 When the hospital identifies Life Safety Code deficiencies that cannot be immediately corrected or during periods of construction, the hospital does the following: Inspects exits in affected areas on a daily basis. The need for these inspections is based on criteria in the hospital's interim life safety measure (ILSM) policy.

LS.01.02.01 EP 8 When the hospital identifies Life Safety Code deficiencies that cannot be immediately corrected or during periods of construction the hospital does the following: Increases surveillance of buildings, grounds, and equipment, giving special attention to construction areas and storage, excavation, and field offices. The need for increased surveillance is based on criteria in the hospital's interim life safety measure (ILSM) policy.

LS.01.02.01 EP 9 When the hospital identifies Life Safety Code deficiencies that cannot be immediately corrected or during periods of construction the hospital does the following: Enforces storage, housekeeping, and debris-removal practices that reduce the building's flammable and combustible fire load to the lowest feasible level. The need for these practices is based on criteria in the hospital's interim life safety (ILSM) policy.

LS.01.02.01 EP 12 When the hospital identifies Life Safety Code deficiencies that cannot be immediately corrected or during periods of construction, the hospital does the following: Inspects and tests temporary systems monthly. The completion date of the tests is documented. The need for these inspections and tests is based on criteria in the hospital's interim life safety measure (ILSM) policy.

LS.01.02.01 EP 14 The hospital trains those who work in the hospital to compensate for impaired structural or compartmental safety features. The need for training is based on criteria in the hospital's interim life safety measures (ILSM) policy.